

OAR 581-022-2223 requires that Scappoose School District 1J create a Safe and Healthy Schools Plan. All components of the District plan are based upon the model plan developed by the Oregon Department of Education.

1. Responsible Person

The person responsible for maintaining and implementing the Healthy and Safe Schools Plan is :

Name: Mitch Neilson

Position: Business Manager

Contact Information:

Address: 33589 SE High School Way, Scappoose, OR 97056

Email: mneilson@scappoose.k12.or.us

Phone: 971-200-8000

2. List Of Buildings

This plan covers the following buildings:

| | |
|--------------------------|--|
| Warren Elementary | 34445 Berg Road, Warren OR 97053 |
| Grant Watts Elementary | 52000 SE Third Place, Scappoose OR 97056 |
| Otto Petersen Elementary | 52050 SE Third Street, Scappoose OR 97056 |
| Scappoose Middle School | 52265 S Columbia River Hwy, Scappoose OR 97056 |
| Scappoose High School | 33700 Se High School Way, Scappoose OR 97056 |
| District Office | 33589 SE High School Way, Scappoose OR 97056 |
| Sauvie Island School | 14445 NW Charlton Road, Portland OR 97231 |

3. Radon

Scappoose School District has adopted a radon plan as required by ORS 332.167. Community members can access a copy of the radon plan here: www.scappoose.k12.or.us. Test results will be made public and posted to the district website as they are completed in

accordance with the schedule set forth in the model plan recommended by the Oregon Health Authority.

4. Lead in Drinking Water

Scappoose School District will test and monitor for lead in drinking water in all school buildings. Samples will be taken of all drinking and food preparation water sources. Samples will be processed by an approved laboratory in accordance with the EPA lead in drinking water testing protocols. The EPA's 3Ts technical guidance plan will be utilized as an element testing protocol.

Water testing results that identify a source containing more than 20 parts per billion (ppb) of lead will trigger prevention of access to that particular water source until follow up testing can be completed and the situation is corrected.

Results of lead water testing will be made available to the public upon request. A report of testing findings will be placed on the district website.

Initial testing was completed June of 2016 in all buildings. All test results were below the EPA threshold for lead in drinking water.

5. Lead Paint

In order to comply with the US Environmental Protection Agency's Renovation, Repair and Painting Program Rule, the district will use certified contractors for such work. The district will provide training to staff to maintain such certification for work performed in house.

6. Integrated Pest Management

The District has adopted an integrated pest management plan as required by ORS 634.700 through 634.750. The plan was designed using the Oregon State University sample plan as a template. District staff has been trained and receive continual recertification as required by the statute. Community members can access a copy of the District IPM plan by contacting the District Office.

7. Communication

The District will make all test results and detailed information explaining the test results available to the public within 5 business days of receiving the results. Results will be made available by posting the results on the District website, sending results via the email system, and making the results available in hardcopy at the main administration office.

8. ESD/Charter Schools

ESD and charter schools which are responsible for their own buildings will provide for their own Safe and Healthy Schools Plan as it pertains to their individual operations. Where applicable, the District plan may be referenced for compliance purposes.